

# Declaration of Conformity

## Harmonic Currents

Inverter: **SolarMax 2000S / 3000S**

Company: Sputnik Engineering AG  
Länggasse 85  
CH-2504 Biel-Bienne


Relevant standard: EN 61000-3-2

### Measured values:

Ratio between harmonic currents ( $I_n$ ) and fundamental harmonic current ( $I_1$ )

Harmonic number [n]	2	3	4	5	6	7	8	9	10	11	12	13	14
$I_n / I_1$ [%]	0.10	0.30	0.08	0.31	0.03	0.34	0.03	0.28	0.02	0.17	0.03	0.13	0.02
Harmonic number [n]	15	16	17	18	19	20	21	22	23	24	25	26	27
$I_n / I_1$ [%]	0.13	0.02	0.09	0.02	0.09	0.02	0.06	0.01	0.07	0.01	0.07	0.01	0.05
Harmonic number [n]	28	29	30	31	32	33	34	35	36	37	38	39	40
$I_n / I_1$ [%]	0.01	0.04	0.02	0.05	0.01	0.04	0.01	0.02	0.01	0.03	0.00	0.03	0.01

Harmonic currents at rated output power  
SolarMax 2000S / 3000S  
(Class A)



Biel/Bienne, 11.03.2013

Sputnik Engineering AG

Andreas Mader